



TÜRKAK - TÜRK AKREDİTASYON KURUMU tarafından akredite
Accredited by TÜRKAK

TSE DENEY ve KALİBRASYON MERKEZİ BAŞKANLIĞI
Makina ve Yapı Malzemeleri Grup Başkanlığı
Yapı Malzemeleri Yangın ve Akustik Laboratuvarı Müdürlüğü

Adres: Aydınlı Mah. Gülenür Sok. No: 7/1 Tuzla/ İSTANBUL
Tel: +90 (216) 560 05 27 Fax: +90 (216) 560 05 65 E-posta: yalitim@tse.org.tr Web: www.tse.org.tr



HEADSHIP OF TSE TEST and CALIBRATION CENTER
CONSTRUCTION MATERIALS FIRE AND ACOUSTICS LABORATORY DIRECTORATE

Address: Aydınlı Mah. Gülenür Sok. No: 7/1 Tuzla/ İSTANBUL
Tel: +90 (216) 560 05 27 Fax: +90 (216) 560 05 65 E-mail: yalitim@tse.org.tr Web: www.tse.org.tr

AB-0001-T
339190
04-17

MUAYENE VE DENEY RAPORU
TEST REPORT

Deneysel Talep Eden : İSONEM YAPI KİMYASALLARI VE BOYA SAN.TİC.LTD.ŞTİ.
(Adı, Adresi, Şehir vb.)
Customer (Name, Address, City etc.) (İSONEM YAPI KİMYASALLARI VE BOYA SAN.TİC.LTD.ŞTİ.: İTOB OSB 10001 SOK. NO:20 TEKELİ Menderes-İZMİR)

Deneysel Talep Tarihi/No : 01.10.2015 / 137384
Order Date / No

Numunenin Tanımı : ÇELİK YAPILAR İÇİN YANGINA DAYANIKLI KABARAN BOYA, İSONEM ANTİFİRE PAINT PLUS , ,
(Cins, Marka, Tip, Tür, Model vb.) - , - , 6,00 adet
Sample Description (Type, Mark, Model etc.) INTUMESCENT FIRE RESISTANCE PAINT FOR STEEL STRUCTURES, İSONEM ANTİFİRE PAINT PLUS, , , 6,00 item

Numune Kabul Tarihi : 01.10.2015
Test Item Receipt Date
Specimens were taken by client

Deneysel Yapıldığı Tarih : 01.03.2017 - 01.03.2017
Date of Test

Uygulanan Standard / Metod : TS EN 13381-8:2013:2013-12 Yapı elemanlarının yangına dayanımına katkısının tayini için deney yöntemi - Bölüm 8: Çelik elemanlara uygulanmış reaktif koruma
Applied Standard/Method TS EN 13381-8:2013:2013-12 Test methods for determining the contribution to the fire resistance of structural members - Part 8: Applied reactive protection to steel members

Raporun Sayfa Sayısı : 12 (40 sayfa ek)
Number of pages of the report

Açıklamalar :
Remarks

Türk Akreditasyon Kurumu (TÜRKAK) deney raporlarının tanınması konusunda Avrupa Akreditasyon Birliği (EA) ve Uluslararası Laboratuvar Akreditasyon Birliği (ILAC) ile karşılıklı tanınma antlaşmasını imzalamıştır.
The Turkish Accreditation Agency (TURKAK) is signatory to the multilateral agreements of the European co-operation for the Accreditation (EA) and of the International Laboratory Accreditation (ILAC) for the Mutual recognition of test reports.
Deney ve/veya ölçüm sonuçları, genişletilmiş ölçüm belirsizlikleri (olması halinde) ve deney metodları bu raporun tamamlayıcı kısmı olan takip eden sayfalarda verilmiştir.

The test and/or measurement results, the uncertainties (if applicable) with confidence probability and test methods are given on the following pages which are part of this report.

Bu rapor özel deney talebine istinaden düzenlenmiş olup, Standartlara Uygunluk Belgesi niteliğinde değildir. Partiyi temsil etmez, ayrıca ilan, reklam ve ihalelerde uygunluk belgesi niteliğinde kullanılamaz.

This test report was prepared upon customer's request, can not be used as certificate of conformity to standards, does not represent a batch and can not be used as conformity document for advertisements and procurements.



Deneysel Sorumlusu
Person in charge of tests

Ahmet Fazıl KARA
Uzman Yardımcısı

Kontrol Eden
Reviewer

Halil Alper YILDIRIM
Mühendis

Onaylayan
Approved by

Metehan ÇALIŞ
Laboratuvar Müdürü

Bu rapor, hazırlayan laboratuvarın yazılı izni olmadan kısmen kopyalanıp çoğaltılamaz. İmzasız ve mühürsüz raporlar geçersizdir.

Bu rapor, sadece deneyi yapılan numune için geçerlidir ve "Ürün Belgesi" yerine geçmez.

This test report shall not be reproduced other than in full except with the written permission of the laboratory. Test reports without signature and seal are not valid.

This test report represents only tested sample(s), and shall not be used as Product Certificate



MUAYENE - DENEY SONUÇLARI TEST RESULTS

CONTENT

	<u>Page</u>
SUMMARY	3
1. TEST SPECIMEN.....	4
2. TEST EQUIPMENT	4
3. TEST CONDITIONS	4
4. TEST SPECIMENS	4
5. INSTALLATION OF THE TEST SPECIMEN	5
6. CONDITIONING.....	5
7. APPLICATION OF INSTRUMENTATION	5
8. TEST PROCEDURE.....	6
9. TEST RESULTS	7
10. MEASUREMENT OF PROPERTIES OF FIRE PROTECTION MATERIALS	7
11. FIXING OF THERMOCOUPLES TO STEEL WORK	7
12. CORRECTION OF DATA	7
13.METHODS OF ASSESSMENT OF FIRE PROTECTION SYSTEM PERFORMANCE..	7
14. PHOTOS	7
15. REFERENCE LIST.....	12





MUAYENE - DENEY SONUÇLARI TEST RESULTS

SUMMARY

ORDER /SPECIMEN NO 137384/ 268220
SPONSOR ISONEM YAPI KİMYASALLARI VE BOYA SAN. TİC. LTD. ŞTİ.
PURPOSE Fire resistance performance of intumescent painting as per TS EN 13381-8
TEST LABORATORY TSE Construction Material Fire and Acoustic Laboratory Management
ADDRESS Aydınlı Mah. Gülenur Sok. No:7/1 Tuzla / İSTANBUL

ABOUT TEST SPECIMEN

General:

“ISONEM ANTI FIRE PAINT PLUS” intumescent paint manufactured by ISONEM YAPI KİMYASALLARI VE BOYA SAN. TİC. LTD. ŞTİ applied to steel sections were tested as per TS EN 13381-8 test method in 01.03.2017 in TSE Construction Material Fire and Acoustic Laboratory.

Application:

Primer, intumescent paint and top coat applied with roller.

Sampling:

Laboratory did not make sampling.

Conditioning:

Specimens were conditioned 28 days in laboratory conditions.



Handwritten signature



MUAYENE - DENEY SONUÇLARI TEST RESULTS

1. TEST SPECIMEN

1.1. GENERAL

“ISONEM ANTI FIRE PAINT PLUS” intumescent paint manufactured by ISONEM YAPI KİMYASALLARI VE BOYA SAN. TİC. LTD. ŞTİ applied to steel sections with roller.

1.2. MATERIALS

Primer coat: Two component grey colour primer coat

Intumescent coat: Isonem Anti Fire Paint Plus

Top coat: Isonem Anti Fire Paint

Steel grade: S275JR

2. TEST EQUIPMENT

Furnace and test equipment are as per TS EN 1363-1

3. TEST CONDITIONS

3.1. GENERAL

The test conditions are as per TS EN 1363-1 and the test standard.

3.2. RESTRAINT AND LOADING CONDITIONS

Loading beam restrained simply supported as per TS EN 13381-8 Figure-2. (**Annex-1**)

Short columns and reference beam hanged furnace roof were tested simultaneously with loading beam. Restraint conditions are as per TS EN 13381-8. (**Annex-2**)

3.3. LOADING

Loading were calculated as per 60% of design moment resistance as per steel certificate values and was performed by 2 point load as per TS EN 1365-3. (**Annex-3**)

4. TEST SPECIMENS

4.1. GENERAL

Short columns and reference beam hanged furnace roof were tested simultaneously with loading beam. Test specimen locations in furnace are given in **Annex-1**.

4.2. TEST SPECIMEN DIMENSIONS

Loading beam dimensions are given in **Annex-1** and are proper as per TS EN 13381-8 Figure 9.

Reference beam and loading beam section dimension are same and cut from same 12m profile.

Short columns are manufactured 1000 mm length as per standard. (**Annex-2**)

4.3. TEST SPECIMEN STEEL CONSTRUCTION

All manufactured steel sections are given in **Annex-1** and **Annex-2**.

4.4. STEEL SECTIONS

All steel sections grades are S275JR.

4.5. PROTECTION MATERIAL PROPERTIES





MUAYENE - DENEY SONUÇLARI TEST RESULTS

Intumescent paint thicknesses are given in **Annex-4** and are in tolerance as per TS EN 13381-8.

4.6. TEST SPECIMEN SELECTION

Test specimens are selected as per TS EN 13381-8 Table 1(Test package 3A) and Table 2 section factor range for one protection thickness.

5. INSTALLATION OF THE TEST SPECIMEN

5.1. LOADING BEAM

Loading beam top insulated with ceramic wool and 15 cm thick and 60 cm length and 500 kg/m³ aerated concrete blocks.

5.2. REFERENCE BEAM

Loading beam top insulated with ceramic wool and 15 cm thick and 60 cm length and 500 kg/m³ aerated concrete blocks and back and front side coated with ceramic wool.

5.3. SHORT COLUMNS

Short columns top and bottom side coat with ceramic wool as per standard.

5.4. TEST SPECIMEN INSTALLATION LAYOUT

Loading beam and reference beam installed parallel to same furnace.

Furnace dimensions are 4,05 m length, 3,70 m width and 2,05 m depth. Depth of the furnace increased 60-30 cm in order to close the loading beam.

Specimens located to furnace in order not to close the burners.

5.5.FURNACE LOAD

Furnace load details are given in **Annex-5**.

6. CONDITIONING

Specimens were conditioned 28 days in laboratory conditions.

7. APPLICATION OF INSTRUMENTATION

7.1. GENERAL

Temperature and pressure measurement equipment are as defined in TS EN 1363-1.

7.2. FURNACE TEMPERATURE CONTROL EQUIPMENT

Furnace temperature control is as defined in TS EN 1363-1.

7.3. EQUIPMENT FOR STEEL TEMPERATURE

Ceramic coated 1200 °C fire retardant 0,8 mm K type thermocouples were used for temperature measurement. Thermocouple locations for loading beam, reference beam and short column are given in **Annex-8**.

7.4. EQUIPMENT FOR PRESURE MEASUREMENT

1 pressure sensor is set 20 Pa under loading beam for furnace pressure measurement. Pressure is set 12,7 Pa (0,85mx8,5 Pa=7,225 Pa; 20 Pa-7,225 Pa= 12,7 Pa), because distance between





MUAYENE - DENEY SONUÇLARI TEST RESULTS

pressure sensor and 10 cm from beam bottom flange is 85 cm. Pressure in test is in limit as per TS EN 1363-1 and given in **Annex-9**.

7.5. EQUIPMENT FOR DISPLACEMENT MEASUREMENT

Displacement measurement were performed with lasers in two location in mid span of the loading beam as per TS EN 1363-1.

7.6. EQUIPMENTS FOR LOADING

Loading was performed with hydraulic system as per TS EN 1363-1 with two point load.

8. TEST PROCEDURE

8.1. GENERAL

Test specimens were selected as per TS EN 13381-8. Section detail are given in **Annex-10**.

8.2. FURNACE TEMPERATURE

Time-temperature graphics and deviation are given in **Annex-6 and Annex-7**.

Furnace temperature was controlled with 8 thermocouples located to loading beam 1/5, 2/5, 3/5 and 4/5 length distance. Time-temperature graphics are given in **Annex-6**

8.3. LOAD APPLICATION AND CONTROL

Load (242KN) calculation detail given in **Annex-3** is performed with hydraulic by two point load. When beam mean temperature come approximately 575 °C, rate of deflection exceeded $l^2/9000d = 4150^2/(9000*400) = 4,78$ mm in 33. Minutes. After that, load were decreased gradually. Loading graphic is given in **Annex-11**.

8.4. STEEL TEMPERATURES

Loading beam temperature graphics are given in **Annex-14**.

Reference beam temperature graphics are given in **Annex-15**.

Short column-IPE 100 temperature graphics are given in **Annex-16**.

Short column- HEA 200 temperature graphics are given in **Annex-17**.

Short column- HEB 240 temperature graphics are given in **Annex-18**.

Short column- HEM 240 temperature graphics are given in **Annex-19**.

8.5. DISPLACEMENT

Displacement values are given in **Annex-13**. Rate of deflection values are given in **Annex-12**.

8.6. OBSERVATIONS

Load was decreased gradually in 33.minute because rate of deflection exceeded limit.

After the test intumescent coating thicknesses were measured approximately 4 cm.

8.7. TERMINATION OF TEST

When all sections temperature exceeded 750 °C, the test was terminated.

9. TEST RESULTS

2 thermocouples for reference beam and 1 thermocouple for short column were detached. But, as per TS EN 13381-8, these detachments are in limit.

Test results and calculation steps are given in annexes.





MUAYENE - DENEY SONUÇLARI TEST RESULTS

10. MEASUREMENT OF PROPERTIES OF FIRE PROTECTION MATERIALS

Intumescent paint thicknesses are given in **Annex-4** and are in limit as per TS EN 13381-8.

11. FIXING OF THERMOCOUPLES TO STEEL WORK

Ceramic coated 1200 °C fire retardant 0,8 mm K type thermocouples were used and installed before application of paint for temperature measurement. Thermocouple locations for loading beam, reference beam and short column are given in **Annex-8**.

12. CORRECTION OF DATA

Data for correction and calculation steps are given in **Annex-20, Annex-21, Annex-22, Annex-23 and Annex-24**.

13. METHODS OF ASSESSMENT OF FIRE PROTECTION SYSTEM PERFORMANCE

Numerical regression analysis were used for assessment. Calculation methods regarding the calculation steps and criteria in TS EN 13381-8 are given in **Annex-25 Step-0, Annex-26 Step-1, Annex-27 Step-2&3, Annex-28 Step-4, Annex-29 (A, B, C, D, E, F) Step-5&6**.

14. PHOTOS



Figure 1. Furnace installation





MUAYENE - DENEY SONUÇLARI *TEST RESULTS*



Figure 2. Furnace installation



Figure 3. Furnace installation





MUAYENE - DENEY SONUÇLARI TEST RESULTS



Figure 4. Furnace installation



Figure 5. Furnace installation





MUAYENE - DENEY SONUÇLARI TEST RESULTS



Figure 6. Specimens during the test



Figure 7. Specimens after the test





MUAYENE - DENEY SONUÇLARI TEST RESULTS



Figure 8. Specimens after the test





MUAYENE - DENEY SONUÇLARI **TEST RESULTS**



Figure 9. Specimens after the test

15. REFERENCE LIST

TS EN 1363-1: Fire resistance test - Part 1 – General requirements



TS EN 13381-8: Test methods for determining the contribution to the fire resistance of structural members - Part 8: Applied reactive protection to steel members

TS EN 13501-2: Fire classification of construction products and building elements - Part 2: Classification using data from fire resistance tests, excluding ventilation services

LAB-D-17-FR-006: Fire resistance raw data form




EK 1-YÜKLEMELİ KİRİŞ DETAYI VE FIRIN NUMUNE LOKASYONU
ANNEX 1-LOAD BEARING BEAM DETAIL AND FURNACE SPECIMEN LOCATION





Talip no: 137384



EK 2-REFERANS KIRIŞ VE KISA KOLON DETAYI ANNEX 2-REFERENCE BEAM AND SHORT COLUMN DETAIL



RERERANS KIRIŞ
RERERENCE BEAM



KISA KOLON
SHORT COLUMN



Taky no: 137384
Order no:


BEAM (open section) - LOAD CALCULATION (in accord. EN 1991-1-1)

1. Static

L_{sup}	4150	[mm]
P_{dist}	2000	[mm]
P_{sup}	1075	[mm]
P distance is OK		

2. Cross-section parameters and steel grade

IPE 400			Actual steel yield strength			275	[MPa]
h	400,0	[mm]	$I_{y,c}$	23130	[cm ⁴]	$W_{el,y,c}$	1160 [cm ³]
b	180,0	[mm]	$I_{z,c}$	1318	[cm ⁴]	$W_{el,z,c}$	[cm ³]
t_w	8,6	[mm]	$I_{w,c}$	490000	[cm ⁶]	$W_{pl,y,c}$	1307 [cm ³]
t_f	13,5	[mm]	$I_{T,c}$	51,1	[cm ⁴]	$W_{pl,z,c}$	[cm ³]
r	21,0	[mm]	i_y	16,6	[cm]	A_c	84,5 [cm ²]
d	331,0	[mm]	i_z	3,95	[cm]	U	[cm]



3. Dead load calculation

Fire protection material parameters	- shape*	c	
	- density	500	[kg/m ³]
	- thickness	1,50	[mm]

* type: "b" for box, "c" for contour

Concrete topping parameters	- density	500	[kg/m ³]
	- width	60	[cm]
	- thickness	15	[cm]

Beam self-weight	66,3	[kg/m]
Concrete topping	45,0	[kg/m]

Fire protection material	1,0	[kg/m]
Additional linear load	0,0	[kg/m]

4. Moment resistance

Cross section class
1

t_{max}	13,5	[mm]
ϵ	0,924	[-]

web c/t	$38,5 \leq 72\epsilon = 66,6$
flange c/t	$4,8 \leq 9\epsilon = 8,3$

$M_{c,y,Rd}$	359,4	[kNm] - plastic
--------------	--------------	-----------------

E	210000	N/mm ²
G	80770	N/mm ²

5. Critical moment for lateral torsional buckling

k	1,0	[-]	- since the compression flange is free to rotate about the weak axis of the cross-section
k_w	1,0	[-]	- since there is no device to prevent the warping at the ends of the beam

C_1	1,127	[-]
C_2	0,454	[-]

z_g	200	[mm]
-------	-----	------

$$M_{cr} = C_1 \frac{\pi^2 EI_z}{(kL)^2} \left\{ \sqrt{\left(\frac{k}{k_w} \right)^2 \frac{I_{\omega}}{I_z} + \frac{(kL)^2 GI_T}{\pi^2 EI_z}} + (C_2 z_g)^2 - C_2 z_g \right\}$$

M_{cr}	315,5	[kNm]
----------	--------------	-------

Stamp:
 Telephone: 137334
 Order no:

6. Non-dimensional slenderness and reduction factor

λ_{LT}	1,067	[-]
$\lambda_{LT,0}$	0,4	[-]
β	0,75	[-]
λ_{LT}	>	$\lambda_{LT,0}$

h/b	2,222	[-]
h/b_{limit}	2,0	[-]

h/b	>	h/b_{limit}
-------	---	---------------

k_c	0,94	[-]
-------	------	-----

f	0,974	[-]
-----	-------	-----

curve c		
α_{LT}	0,49	[-]
Φ_{LT}	1,091	[-]
χ_{LT}	0,599	[-]
χ_{LT}	0,599	[-]
$\chi_{LT,mod}$	0,615	[-]

before checks

after checks

7. Design buckling resistance moment

$M_{c,y,Rd}$	220,9	[kNm]
$V_{c,z,Rd}$	678,4	[kN]

No M-V interaction has to be considered since the maximum moment is obtained at mid-span and the maximum shear force is obtained at supports

8. Force in the test

60% $M_{c,y,Rd}$	132,6	[kNm]	=	"P" force momentum	130,1	[kNm]
—						
Dead load momentum	2,5	[kNm]				

Load required to be applied in the fire test (in addition to the dead load)	P	242,0	[kN]
Note: One hydraulic ram applies half of the value P !!!			



Talep no : 137 384
Order no

THICKNESS OF FIRE PROTECTION MATERIAL - LOADED BEAM (OPEN SECTION)

Basic Information	Order No.	137384		LB-1	
	Name of the company	ISONEM			
	Fire protection system	Isonem Antifire Paint Plus			
	Layers	Intumescent		IPE 400	

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit		Result
	1620	1239	1989	1296	1944	1134	2106	891	2349	±20%	±30%	±45%
	Deviation =		23,5%	Requirements		891	2106	891	2349	98%	100%	100%
	Requirements			Requirements		1134	2106	891	2349	68%	95%	100%

Measurement no.:	Measuring points											% of readings within limit		
	1	2	3	4	5	6	7	8	9	10	11	±20%	±30%	±45%
1. Position 1 temperature measurement station	1591	1871	1528	1485	1579	1517	1331	1422	1579	1517	1331	88%	100%	100%
2. Position 2 temperature measurement station	1643	1653	1641	1616	1555	1776	1614	1701	1555	1776	1614	100%	100%	100%
3. Position 3 temperature measurement station	1529	1700	1638	1777	1741	1806	1579	1506	1741	1806	1579	100%	100%	100%
4. Position A temperature measurement station	1437	1596	1605	1437	1596	1605	1596	1605	1596	1605	1605	100%	100%	100%
5. Position B temperature measurement station	1408	1304	1429	1408	1304	1429	1429	1408	1408	1429	1408	100%	100%	100%
6. Halfway between Position 1 and Position A	1676	1702	1728	1459	1617	1696	1673	1671	1617	1696	1673	100%	100%	100%
7. Halfway between Position A and Position 2	1778	1528	1518	1658	1678	1778	1658	1778	1678	1778	1658	100%	100%	100%
8. Halfway between Position 2 and Position B	1338	1518	1628	1758	1628	1758	1628	1758	1628	1758	1628	100%	100%	100%
9. Halfway between Position B and Position 3	1577	1663	1618	1239	1603	1509	1297	1513	1603	1509	1297	100%	100%	100%
10. Halfway between Position 1 and beam's end	1691	1876	1759	1662	1695	1511	1658	1692	1695	1511	1658	100%	100%	100%
11. Halfway between Position 3 and beam's end	1834	1899	1860	1989	1925	1909	1747	1849	1925	1909	1747	100%	100%	100%
	Requirements											68%	95%	100%



All measurements in [µm]

THICKNESS OF FIRE PROTECTION MATERIAL - UNLOADED BEAM (OPEN SECTION)

Basic Information	Order No.	137384										SIB-1
	Name of the company	ISONEM										
	Fire protection system	Isonem Antifire Paint Plus										
	Layers	Intumescent										
Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit		Result
	1769	1006	2288	1416	2123	1239	2300	973	2566	±20%	±30%	±45%
	Deviation =			43,1%		Requirements		973	2566	75%	96%	100%
						Requirements		973	2566	68%	95%	100%

Measurement no.:	% of readings within limit										
	1	2	3	4	5	6	7	8			
1. Position 1 temperature measurement station	1677	1369	1702	1873	1634	1946	1943	1733	88%	100%	100%
2. Position 2 temperature measurement station	1941	1006	2154	1866	2288	1954	1794	1454	75%	88%	100%
3. Position 3 temperature measurement station	1550	1324	1762	2000	1757	2218	1720	1801	75%	100%	100%
	Requirements								68%	95%	100%

All measurements in [µm]



THICKNESS OF FIRE PROTECTION MATERIAL - UNLOADED COLUMN (OPEN SECTION)

Basic Information	Order No.	137384										SIC-1
	Name of the company	ISONEM										
	Fire protection system	Isonem Antifire Paint Plus										
	Layers	Intumescent										
Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit		Result
	1496	1184	1970	1197	1796	1047	1945	823	2170	80%	95%	100%
	Deviation =			31,7%		Requirements		Requirements		68%	95%	100%

Measuring points	Measurement no.:	10										% of readings within limit		
		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
1. Position 1 temperature measurement station	1184	1441	1557	1644	1645	1310	1272	1770	1909	1218	80%	100%	100%	
2. Position 2 temperature measurement station	1882	1970	1746	1373	1499	1383	1321	1242	1274	1286	80%	90%	100%	
											Requirements	68%	95%	100%

All measurements in [µm]



THICKNESS OF FIRE PROTECTION MATERIAL - UNLOADED COLUMN (OPEN SECTION)

Basic Information	Order No.	137384										SIC-4
	Name of the company	ISONEM										
	Fire protection system	Isonem Antifire Paint Plus										
	Layers	Intumescent										

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit		Result
	1531	1295	2219	1225	1837	1071	1990	842	2219	±20%	±30%	±45%
	Deviation =			45,0%		Requirements		842		90%	95%	100%
						Requirements		842		68%	95%	100%

Measuring points	Measurement no.:										% of readings within limit		
	1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
1. Position 1 temperature measurement station	1458	1945	2219	1450	1501	1295	1415	1355	1458	1756	80%	90%	100%
2. Position 2 temperature measurement station	1553	1335	1412	1363	1450	1542	1412	1773	1505	1416	90%	100%	100%
	Requirements										68%	95%	100%

All measurements in [µm]



THICKNESS OF FIRE PROTECTION MATERIAL - UNLOADED COLUMN (OPEN SECTION)

Basic Information	Order No.	137384										SIC-3	
	Name of the company	ISONEM											
	Fire protection system	Isonem Antifire Paint Plus											
	Layers	Intumescent										HEB 240	

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit		Result		
	1531	1034	1947	1224	1837	1071	1990	842	2219	80%	95%	100%	PASS	
Deviation =	32,4%										Requirements	68%		95%

Measuring points	Measurement no.:	10										% of readings within limit		
		1	2	3	4	5	6	7	8	9	10	±20%	±30%	±45%
1. Position 1 temperature measurement station	1298	1868	1407	1897	1947	1639	1306	1583	1229	1392	70%	100%	100%	
	1309	1474	1034	1350	1645	1510	1824	1579	1808	1512	70%	90%	100%	
Requirements												68%	95%	100%

All measurements in [µm]



THICKNESS OF FIRE PROTECTION MATERIAL - UNLOADED COLUMN (OPEN SECTION)

Basic Information	Order No.	137384										SIC-2	
	Name of the company	ISONEM											
	Fire protection system	Isonem Antifire Paint Plus										HEA 200	
	Layers	Intumescent											

Results	MEAN	MIN	MAX	MEAN -20%	MEAN +20%	MEAN -30%	MEAN +30%	MEAN -45%	MEAN +45%	% of readings within limit		Result
	1605	1134	2054	1284	1926	1124	2087	883	2328	±20%	±30%	±45%
Deviation =			29,4%					Requirements		80%	100%	100%
								Requirements		68%	95%	100%

Measuring points	Measurement no.:	%										Requirements		
		1	2	3	4	5	6	7	8	9	10		±20%	±30%
1. Position 1 temperature measurement station		1682	1750	1676	1663	1714	1690	1661	1650	1666	1373	100%	100%	100%
2. Position 2 temperature measurement station		1273	1599	1592	1961	1487	1672	1134	1494	2054	70%	90%	100%	
		Requirements										68%	95%	100%

All measurements in [µm]



EK- 5 FIRIN YÜKÜ /ANNEX- 5 FURNACE LOAD

Furnace size/Fırın boyutları		
Depth:	2,9	[m]
Width	3	[m]
Lenght	4	[m]
Volume	34,8	[m ³]

Furnace load/Fırın yükü		
Furnace load	18,7	[kg/m ³]
Max furnace load	45,0	[kg/m ³]
41,5%		


OK - FURNACE LOAD WITHIN LIMIT

Test specimens/Test numuneleri					
No.	Symbol	Section	Lenght [m]	Weight [kg/m]	Load [kg]
1	SIC-1	IPE 400	4,42	66,3	293,0
2	SIC-2	IPE 400	1,00	66,3	66,3
3	SIC-3	IPE 100	1,00	8,1	8,1
4	SIC-4	HEM 240	1,00	157,0	157,0
5	SIC-5	HEA 200	1,00	42,3	42,3
6	SIC-6	HEB 200	1,00	83,2	83,2
7					
8					
9					
10					
11					
12					
13					
14					
15					
Total load					649,9

Talep no: 137384
Order no:




FURNACE THERMOCOUPLES
FIRIN ISILÇİFTLERİ



Palet no: 1132334


DEVIATION (FURNACE)
SAPMA (FIRIN)

Annex: 7 EK:7



Talepno : 137386
orderno :

FURNACE PRESSURE
FIRIN BASINCI



Tablo no: AKK dh
Order no: 132326


EK-10 KESİT DETAYLARI / ANNEX-10 SECTION DETAIL

No.	Symbol	Section type/ Kesit tipi	Heating/ Isıtma	Profile/Profil	Measured values/Ölçülmüş değerler							Section factor /Kesit faktörü [m ⁻¹]
					h [mm]	b [mm]	t _f [mm]	t _w [mm]	P [mm]	A [mm ²]		
1	SIC-1	open/açık	4 sides/tafraf	IPE 100	100	55	5,8	4,1	412	1000	412	
2	SIC-2	open/açık	4 sides/tafraf	HEA 200	190	200	10,4	6,5	1167	5260	222	
3	SIC-3	open/açık	4 sides/tafraf	HEB 240	232	242	16,0	11,2	1410	9998	141	
4	SIC-4	open/açık	4 sides/tafraf	HEM 240	270	243	30,5	18,2	1476	18616	79	
5	SIB-1	open/açık	3 sides/tafraf	IPE 400	400	180	13,5	9,6	1321	8441	156	
6	LB-1	open/açık	3 sides/tafraf	IPE 400	400	180	13,5	9,6	1321	8441	156	




Tekno:
Order no: 137384

YÜKLEME DEĞERLERİ / LOADING VALUES (N)



Telefon: 0162 384 157384


YERDEĞİŞTİRME HIZI DEĞERLERİ /DISPLACEMENT RATE VALUES (mm)



Talep no: 137334
Order no: 137334
APK




YERDEĞİŞTİRME DEĞERLERİ /DISPLACEMENT VALUES (mm)



Talep no: 137384
order no: 137384


AFK

LOADED BEAM IPE 400




Telefon: 137334
Order no: 137334

IPE 400 REFERANS KIRIŞ /REFERENCE BEAM




Tel: 0212 234 3344
Fax: 0212 234 3344

IPE 100




Taahhüt no: 137324
Order no: 137324

HEA 200




Tablo no: 137554
Ordn no:

HEB 240



Talgut 401
Order no: 13730-4

HEM 240



Talimat no: 137324
Order no: 137324

EK-20 VERİLERİN DOĞRULANMASI / ANNEX-20 DATA CORRECTION

Element	Section/ Kesit	Length/ Boy [mm]	Protection shape/Koruma şekli	Nominal protection thickness Nominal koruma kalınlığı dp [mm]	Real protection thickness/Gerç ek koruma kalınlığı [mm]	Nominal section factor/Nominal kesit faktörü Am/V [m-1]	Real section factor/Gerçek kesit faktörü [m-1]
TEST 1							
SIC-1	IPE 100	1000	Contour/Tüm çevre	1,500	1,496	416	412
SIC-2	HEA 200	1000	Contour/Tüm çevre	1,500	1,605	229	222
SIC-3	HEB 240	1000	Contour/Tüm çevre	1,500	1,531	139	141
SIC-4	HEM 240	1000	Contour/Tüm çevre	1,500	1,531	76	79
SIB-1	IPE 400	1000	Contour/Tüm çevre	1,500	1,769	164	156
LB-1	IPE 400	4420	Contour/Tüm çevre	1,500	1,620	164	156



Talep no: 137384
Order no: 137384

EK-21 DOĞRULAMA FAKTÖRÜ / ANNEX-21 CORRECTION FACTOR

Section Type / Parameter	Thickness/ Kalinlık [mm]	Section Factor/Kesit Faktörü [m ⁻¹]	Time (characteristic) to reach design temperature [min]/Dizayn sıcaklığına ulaşılan zaman [dak]										Failure time/Kalma zamanı (EN 1363-1) [min]
			300	350	400	450	500	550	600	650	700	750	
Loaded Element MIN	1,620	156	9,8	12,4	14,9	17,3	19,8	22,6	25,6	29,7	37,6	46,4	32,88333
Reference Element MIN	1,769	156	11,8	15,2	18,3	21,4	24,4	27,3	30,4	33,4	51,0	59,7	
$t_c(d_{min})$	1,620		10,8	13,9	16,7	19,6	22,3	25,0	27,9	30,6	46,7	54,6	
k_{min}	1,620		0,91	0,89	0,89	0,89	0,89	0,91	0,92	0,97	0,80	0,85	



Tel no: 0212 334 1373

EK-22 DOĞRULAMA TABLOSU / ANNEX-22 CORRECTION FACTOR TABLE

Correction factor/Düzeltilme faktörü k_f													
Test	Element	Section factor/Kesit faktörü	Thickness/Kalınlık	300	350	400	450	500	550	600	650	700	750
Test 1	SIC-1	412	1,496	0,91	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89
	SIC-2	222	1,605	0,91	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89
	SIC-3	141	1,531	0,91	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89
	SIC-4	79	1,531	0,91	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89	0,89

CORRECTION FACTOR TABLE



Talgay no: 137384
Ordu no:

EK-23 SICAKLIK-ZAMAN DEĞERLERİ / ANNEX-23 TIME TO REACH

Time to reach design temperature [min] Dziayn sıcaklığına ulaşılan zaman (dak)													
Test	Element	Section factor/Kesit faktörü	Thickness/Kalınlık	300	350	400	450	500	550	600	650	700	750
Test 1	SIC-1	412	1,496	10,7166667	15,85	20,0166667	23,9333333	27,8333333	31,7	35,8	40,3666667	45,7666667	52,85
	SIC-2	222	1,605	17,9333333	23,55	28,6666667	33,4166667	38,3833333	43,7	49,5	55,8333333	63,1666667	72,41667
	SIC-3	141	1,531	21,3166667	26,7166667	32,1166667	37,7	43,5333333	49,5666667	56,0833333	63,4166667	72,2	82,63333
	SIC-4	79	1,531	27,1666667	34,6166667	41,2833333	48,3	56,1333333	64,5166667	73,2666667	82,25	91,7666667	103,0667

BASED ON TEST DATA (BEFORE CORRECTION) (DÜZELTMEYEN ÖNCE)



Talep no: 137384
order no: 137384

EK-24 SICAKLIK-ZAMAN DEĞERLERİ (DOĞRULANMIŞ) / ANNEX-24 TIME TO REACH (CORRECTED)

Test	Element	n factor/Kesit	Thickness/ Kalınlık	Time to reach design temperature [min] Diziğin sıcaklığına ulaşılan zaman (dak)											
				300	350	400	450	500	550	600	650	700	750		
Test 1	SIC-1	412	1,496	9,74	14,06	17,83	21,20	24,69	28,21	31,86	35,93	40,73	47,04		
	SIC-2	222	1,605	16,30	20,89	25,53	29,60	34,05	38,89	44,06	49,69	56,22	64,45		
	SIC-3	141	1,531	19,37	23,70	28,61	33,40	38,62	44,11	49,91	56,44	64,26	73,54		
	SIC-4	79	1,531	24,69	30,71	36,77	42,79	49,80	57,42	65,21	73,20	81,67	91,73		

AFTER CORRECTION (DÜZLETMEDEN SONRA)



Tel no: 137384

INPUT DATA

No	Element	Am/V [m-1]	dp [mm]	Time to reach design temperature (corrected) [°C]											
				300	350	400	450	500	550	600	650	700	750		
1	SIC-1	412	1,5	9,74	14,06	17,83	21,20	24,69	28,21	31,86	35,93	40,73	47,04		
2	SIC-2	222	1,5	16,30	20,89	25,53	29,60	34,05	38,89	44,06	49,69	56,22	64,45		
3	SIC-3	141	1,5	19,37	23,70	28,61	33,40	38,62	44,11	49,91	56,44	64,26	73,54		
4	SIC-4	79	1,5	24,69	30,71	36,77	42,79	49,80	57,42	65,21	73,20	81,67	91,73		



Talep no:
Order no: 137384

Element	AmV	dp	temp	dp	dp/AmV	temp	dp*temp	dp*(temp/AmV)	temp/AmV	1/AmV	time
SIC-1	412	1,5	300	1,5	0,003640777	300	450	1,9922301	0,72815534	0,002427184	9,74
SIC-1	412	1,5	350	1,5	0,003640777	350	525	1,274271845	0,848514563	0,002427184	14,06
SIC-1	412	1,5	400	1,5	0,003640777	400	600	1,45631068	0,970873786	0,002427184	17,83
SIC-1	412	1,5	450	1,5	0,003640777	450	675	1,638349515	1,09223301	0,002427184	21,20
SIC-1	412	1,5	500	1,5	0,003640777	500	750	1,82038835	1,213592233	0,002427184	24,69
SIC-1	412	1,5	550	1,5	0,003640777	550	825	2,002427184	1,348951456	0,002427184	28,21
SIC-1	412	1,5	600	1,5	0,003640777	600	900	2,184466019	1,45631068	0,002427184	31,86
SIC-1	412	1,5	650	1,5	0,003640777	650	975	2,366504854	1,577669903	0,002427184	35,93
SIC-1	412	1,5	700	1,5	0,003640777	700	1050	2,548543689	1,699029126	0,002427184	40,73
SIC-1	412	1,5	750	1,5	0,003640777	750	1125	2,730582524	1,82038835	0,002427184	47,04
SIC-2	222	1,5	300	1,5	0,006756757	300	450	2,027027027	1,351351351	0,004504505	16,30
SIC-2	222	1,5	350	1,5	0,006756757	350	525	2,364864865	1,576576777	0,004504505	20,89
SIC-2	222	1,5	400	1,5	0,006756757	400	600	2,702702703	1,801801802	0,004504505	25,53
SIC-2	222	1,5	450	1,5	0,006756757	450	675	3,040540541	2,027027027	0,004504505	29,60
SIC-2	222	1,5	500	1,5	0,006756757	500	750	3,378378378	2,252252252	0,004504505	34,05
SIC-2	222	1,5	550	1,5	0,006756757	550	825	3,716216216	2,477477477	0,004504505	38,89
SIC-2	222	1,5	600	1,5	0,006756757	600	900	4,054054054	2,702702703	0,004504505	44,06
SIC-2	222	1,5	650	1,5	0,006756757	650	975	4,391891892	2,927927928	0,004504505	49,69
SIC-2	222	1,5	700	1,5	0,006756757	700	1050	4,729729729	3,153153153	0,004504505	56,22
SIC-2	222	1,5	750	1,5	0,006756757	750	1125	5,067567568	3,378378378	0,004504505	64,45
SIC-3	141	1,5	300	1,5	0,010638298	300	450	3,191489362	2,127859574	0,007092199	23,70
SIC-3	141	1,5	350	1,5	0,010638298	350	525	3,723404255	2,482269504	0,007092199	27,70
SIC-3	141	1,5	400	1,5	0,010638298	400	600	4,255319149	2,836879433	0,007092199	32,61
SIC-3	141	1,5	450	1,5	0,010638298	450	675	4,787234043	3,191489362	0,007092199	37,40
SIC-3	141	1,5	500	1,5	0,010638298	500	750	5,319148936	3,546099291	0,007092199	42,11
SIC-3	141	1,5	550	1,5	0,010638298	550	825	5,85106383	3,90070922	0,007092199	47,11
SIC-3	141	1,5	600	1,5	0,010638298	600	900	6,382978723	4,255319149	0,007092199	52,11
SIC-3	141	1,5	650	1,5	0,010638298	650	975	6,914893617	4,609929078	0,007092199	57,44
SIC-3	141	1,5	700	1,5	0,010638298	700	1050	7,446808511	4,964539078	0,007092199	62,66
SIC-3	141	1,5	750	1,5	0,010638298	750	1125	7,978723404	5,319148936	0,007092199	68,54
SIC-4	79	1,5	300	1,5	0,018987342	300	450	5,696202532	3,797468354	0,012658228	24,69
SIC-4	79	1,5	350	1,5	0,018987342	350	525	6,64556962	4,430379747	0,012658228	30,71
SIC-4	79	1,5	400	1,5	0,018987342	400	600	7,594936709	5,063291139	0,012658228	36,77
SIC-4	79	1,5	450	1,5	0,018987342	450	675	8,544303797	5,696202532	0,012658228	42,79
SIC-4	79	1,5	500	1,5	0,018987342	500	750	9,493670886	6,329113924	0,012658228	49,80
SIC-4	79	1,5	550	1,5	0,018987342	550	825	10,44303797	6,962025316	0,012658228	57,42
SIC-4	79	1,5	600	1,5	0,018987342	600	900	11,39240506	7,594936709	0,012658228	65,21
SIC-4	79	1,5	650	1,5	0,018987342	650	975	12,34177215	8,227848101	0,012658228	73,20
SIC-4	79	1,5	700	1,5	0,018987342	700	1050	13,29113924	8,860759494	0,012658228	81,67
SIC-4	79	1,5	750	1,5	0,018987342	750	1125	14,24050633	9,493670886	0,012658228	91,73

A7	A8	A5	A4	A3	A2	A1	A0
0	0	4,270291	0,045875	0	-510,009	0	-12,5317
0	0	0,541493	0,008186	0	294,728	0	3,400897
R2--> 0,980417	2,826857	HYOK	HYOK	HYOK	HYOK	HYOK	HYOK
614,1933	36	HYOK	HYOK	HYOK	HYOK	HYOK	HYOK
14724,28	287,6804	HYOK	HYOK	HYOK	HYOK	HYOK	HYOK
0							
0							
A7	A6	A5	A4	A3	A2	A1	A0
0	0	4,270291	0,045875	0	-510,009	0	-12,5317



Telefon: 0/daş no: 137384

INPUT DATA (from Step 0)

No.	Element	AnvV [m-1]	dp [mm]	Time to reach design temperature CORRECTED [°C]										
				300	350	400	450	500	550	600	650	700	750	
1	SIC-1	412	1.5	9.7	14.1	17.8	21.2	24.7	28.2	31.9	35.9	40.7	47.0	
2	SIC-2	222	1.5	16.3	20.9	25.5	29.6	34.1	38.9	44.1	49.7	56.2	64.5	
3	SIC-3	141	1.5	19.4	23.7	28.6	33.4	38.6	44.1	49.9	56.4	64.3	73.5	
4	SIC-4	79	1.5	24.7	30.7	36.8	42.8	49.8	57.4	65.2	73.2	81.7	91.7	

PREDICTED TIMES (Step 2)

No.	Element	AnvV [m-1]	dp [mm]	Time to reach design temperature PREDICTED [°C]										
				300	350	400	450	500	550	600	650	700	750	
1	SIC-1	412	1.5	10.9	15.1	19.4	23.6	27.8	32.0	36.2	40.4	44.7	48.9	
2	SIC-2	222	1.5	13.3	18.2	23.1	28.0	32.9	37.7	42.5	47.5	52.4	57.3	
3	SIC-3	141	1.5	16.3	22.0	27.7	33.5	39.2	44.9	50.6	56.3	62.0	67.7	
4	SIC-4	79	1.5	22.8	30.2	37.7	45.2	52.7	60.2	67.7	75.2	82.7	90.2	

DIFFERENCES (Step 3) (in minutes)

1	SIC-1	412	1.5	1.2	1.1	1.5	2.4	3.1	3.8	4.4	4.5	3.9	1.8
2	SIC-2	222	1.5	-3.0	-2.7	-2.4	-1.6	-1.2	-1.4	-2.2	-2.2	-3.8	-7.2
3	SIC-3	141	1.5	-3.1	-1.7	-0.9	0.1	0.5	0.8	0.7	-0.1	-2.2	-5.8
4	SIC-4	79	1.5	-1.9	-0.5	1.0	2.5	2.9	2.8	2.5	2.0	1.0	-1.5
AVG. DIFF. 0,0000													

DIFFERENCES (Step 3) (in %)

1	SIC-1	412	1.5	12,11%	7,64%	8,56%	13,17%	14,53%	9,34%	15,71%	14,58%	9,65%	3,74%
2	SIC-2	222	1.5	-18,25%	-12,87%	-13,03%	-5,31%	-3,37%	-2,97%	-5,25%	-4,40%	-10,11%	-11,14%
3	SIC-3	141	1.5	-15,77%	-7,07%	-3,01%	0,16%	1,40%	1,22%	1,15%	0,25%	-3,50%	-7,11%
4	SIC-4	79	1.5	-8,33%	-1,63%	2,64%	5,73%	5,84%	4,84%	3,85%	2,75%	1,21%	-1,64%
AVG. DIFF. 0,25%													

ACCEPTABILITY OF ANALYSIS			
Criterion	Description	Value	Test
13.5 a)	predicted time for each element ≤15% larger than corrected time	0	PASSED
13.5 b)	mean value of all percentage differences < 0%	0,25%	FAILED
13.5 c)	maximum of 30% of values >0%	52,50%	FAILED



Tel: 0312 211 10 00
 Order no: 137384
 AH

INPUT DATA (from Step 0)

No	Element	AmV [m-1]	dp [mm]	Time to reach design temperature CORRECTED [°C]										
				300	350	400	450	500	550	600	650	700	750	
1	SIC-1	412	1,5	9,7	14,1	17,8	21,2	24,7	28,2	31,9	35,9	40,7	47,0	
2	SIC-2	222	1,5	16,3	20,9	25,5	29,6	34,1	38,9	44,1	49,7	56,2	64,5	
3	SIC-3	141	1,5	19,4	23,7	28,6	33,4	38,6	44,1	49,9	56,4	64,3	73,5	
4	SIC-4	79	1,5	24,7	30,7	36,8	42,8	49,8	57,4	65,2	73,2	81,7	91,7	

MODIFIED PREDICTED TIMES (Step 4)

No	Element	AmV [m-1]	dp [mm]	Time to reach design temperature MODIFIED & PREDICTED [°C]										
				300	350	400	450	500	550	600	650	700	750	
1	SIC-1	412	1,5	10,5	14,6	18,6	22,7	26,7	30,8	34,9	38,9	43,0	47,0	
2	SIC-2	222	1,5	12,8	17,5	22,2	26,9	31,6	36,3	41,0	45,7	50,4	55,1	
3	SIC-3	141	1,5	15,7	21,2	26,7	32,2	37,7	43,2	48,7	54,2	59,7	65,2	
4	SIC-4	79	1,5	21,9	29,1	36,3	43,5	50,7	57,9	65,2	72,4	79,6	86,8	

DIFFERENCES (Step 4) (in minutes)

1	SIC-1	412	1,5	0,8	0,5	0,8	1,5	2,0	2,6	3,0	3,0	2,2	0,0
2	SIC-2	222	1,5	-3,5	-3,4	-3,3	-2,7	-2,4	-2,6	-3,0	-4,0	-5,8	-9,3
3	SIC-3	141	1,5	-3,7	-2,5	-1,9	-1,2	-0,9	-0,9	-1,2	-2,3	-4,6	-8,4
4	SIC-4	79	1,5	-2,8	-1,6	-0,5	0,7	0,9	0,5	0,0	-0,8	-2,1	-4,9
												AVG. DIFF.	-1,5469

DIFFERENCES (Step 4) (in %)

1	SIC-1	412	1,5	7,85%	6,55%	4,44%	5,08%	6,29%	6,37%	6,40%	6,25%	5,50%	4,01%
2	SIC-2	222	1,5	-41,44%	-46,13%	-43,00%	-30,08%	-23,17%	-26,64%	-32,53%	-40,84%	-50,84%	-64,50%
3	SIC-3	141	1,5	-19,89%	-10,99%	-6,70%	-5,07%	-2,87%	-2,17%	-2,49%	-4,49%	-9,14%	-17,00%
4	SIC-4	79	1,5	-11,33%	-6,24%	-1,24%	1,73%	1,89%	0,67%	-0,67%	-1,13%	-2,54%	-5,36%
												AVG. DIFF.	-3,54%

REGRESSION CONSTANTS (from Step 1)							
A7	A6	A5	A4	A3	A2	A1	A0
0,000	0,000	4,270	0,046	0,000	-510,009	0,000	-12,532

MODIFIED REGRESSION CONSTANTS (Step 4)							
A7	A6	A5	A4	A3	A2	A1	A0
0	0	4,1088738	0,0441405	0	-490,7305	0	-12,05796
Modification factor "x" (s1,00)							0,9622

←- modify here

ACCEPTABILITY OF ANALYSIS			
Criterion	Description	Value	Test
13.5 a)	predicted time for each element ≤1.5% larger than corrected time	0	PASSED
13.5 b)	mean value of all percentage differences < 0%	-3,54%	PASSED
13.5 c)	maximum of 30% of values >0%	30,00%	PASSED



EK-29-A ADIM 5&6 /ANNEX-29-A STEP 5&6

15 Dakika

Fire Resistance Period / Yangına Daynım Periyodu 15 minutes/dakika										
Design Temperature/ Dizayn Sıcaklığı °C	300	350	400	450	500	550	600	650	700	750
Section factor/Kesit faktörü m ⁻¹	Thickness (mm) of Fire Protection Material to Maintain Steel Temperature Below Design Temperature/Çeliği istenilen dizayn sıcaklığı altında tutmak için koruma malzemesi kalınlığı (mm)									
71	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
80	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
90	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
100	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
110	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
120	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
130	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
140	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
150	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
160	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
170	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
180	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
190	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
200	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
210	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
220	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
230	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
240	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
250	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
260	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
270	-	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
280	-	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
290	-	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
300	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
310	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
320	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
330	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
340	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
350	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
360	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
370	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
380	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
390	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
400	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
410	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
420	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
430	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
440	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
450	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
453	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4



Talep no: 137384

EK-29-B ADIM 5&6 /ANNEX-29-B STEP 5&6

20 Dakika

Fire Resistance Period / Yangına Daynım Periyodu 20 minutes/dakika										
Design Temperature/ Dizayn Sıcaklığı °C	300	350	400	450	500	550	600	650	700	750
Section factor/Kesit faktörü m ⁻¹	Thickness (mm) of Fire Protection Material to Maintain Steel Temperature Below Design Temperature/Çeliği istenilen dizayn sıcaklığı altında tutmak için koruma malzemesi kalınlığı (mm)									
71	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
80	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
90	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
100	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
110	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
120	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
130	-	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
140	-	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
150	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
160	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
170	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
180	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
190	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
200	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
210	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
220	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
230	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
240	-	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
250	-	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
260	-	1,7	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
270	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
280	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
290	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
300	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
310	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
320	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
330	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
340	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
350	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
360	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
370	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
380	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
390	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
400	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
410	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
420	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
430	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
440	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
450	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
453	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4

Talep no: 132324
Order no: 132324

EK-29-C ADIM 5&6 /ANNEX-29-C STEP 5&6

30 Dakika

Fire Resistance Period / Yangına Daynım Periyodu 30 minutes/dakika										
Design Temperature/ Dizayn Sıcaklığı °C	300	350	400	450	500	550	600	650	700	750
Section factor/Kesit faktörü m ⁻¹	Thickness (mm) of Fire Protection Material to Maintain Steel Temperature Below Design Temperature/Çeliği istenilen dizayn sıcaklığı altında tutmak için koruma malzemesi kalınlığı (mm)									
71	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
80	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
90	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
100	-	1,7	1,4	1,4	1,4	1,4	1,4	1,4	1,4	1,4
110	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
120	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4	1,4
130	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
140	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4	1,4
150	-	-	1,7	1,5	1,4	1,4	1,4	1,4	1,4	1,4
160	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4
170	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4
180	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4
190	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4
200	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4
210	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4
220	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4
230	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4	1,4
240	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4	1,4
250	-	-	-	1,7	1,5	1,4	1,4	1,4	1,4	1,4
260	-	-	-	1,7	1,5	1,4	1,4	1,4	1,4	1,4
270	-	-	-	1,7	1,5	1,4	1,4	1,4	1,4	1,4
280	-	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4
290	-	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4
300	-	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4
310	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
320	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
330	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
340	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
350	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
360	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
370	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
380	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
390	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
400	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
410	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
420	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
430	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
440	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
450	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
453	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4

TÜRKİYE
YATIRIM BANKASI
1954
AFK
Talep no: 137384

EK-29-D ADIM 5&6 /ANNEX-29-D STEP 5&6

45 Dakika

Fire Resistance Period / Yangına Daynım Periyodu 45 minutes/dakika										
Design Temperature/ Dizayn Sıcaklığı °C	300	350	400	450	500	550	600	650	700	750
Section factor/Kesit faktörü m ⁻¹	Thickness (mm) of Fire Protection Material to Maintain Steel Temperature Below Design Temperature/Çeliği istenilen dizayn sıcaklığı altında tutmak için koruma malzemesi kalınlığı (mm)									
71	-	-	1,7	1,5	1,4	1,4	1,4	1,4	1,4	1,4
80	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4	1,4
90	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4	1,4
100	-	-	-	-	1,5	1,4	1,4	1,4	1,4	1,4
110	-	-	-	-	1,6	1,4	1,4	1,4	1,4	1,4
120	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
130	-	-	-	-	1,7	1,5	1,4	1,4	1,4	1,4
140	-	-	-	-	-	1,5	1,4	1,4	1,4	1,4
150	-	-	-	-	-	1,6	1,4	1,4	1,4	1,4
160	-	-	-	-	-	1,6	1,5	1,4	1,4	1,4
170	-	-	-	-	-	1,6	1,5	1,4	1,4	1,4
180	-	-	-	-	-	1,7	1,5	1,4	1,4	1,4
190	-	-	-	-	-	-	1,5	1,4	1,4	1,4
200	-	-	-	-	-	-	1,6	1,4	1,4	1,4
210	-	-	-	-	-	-	1,6	1,5	1,4	1,4
220	-	-	-	-	-	-	1,6	1,5	1,4	1,4
230	-	-	-	-	-	-	1,6	1,5	1,4	1,4
240	-	-	-	-	-	-	1,6	1,5	1,4	1,4
250	-	-	-	-	-	-	1,7	1,5	1,4	1,4
260	-	-	-	-	-	-	1,7	1,5	1,4	1,4
270	-	-	-	-	-	-	1,7	1,6	1,4	1,4
280	-	-	-	-	-	-	-	1,6	1,4	1,4
290	-	-	-	-	-	-	-	1,6	1,5	1,4
300	-	-	-	-	-	-	-	1,6	1,5	1,4
310	-	-	-	-	-	-	-	1,6	1,5	1,4
320	-	-	-	-	-	-	-	1,6	1,5	1,4
330	-	-	-	-	-	-	-	1,6	1,5	1,4
340	-	-	-	-	-	-	-	1,6	1,5	1,4
350	-	-	-	-	-	-	-	1,6	1,5	1,4
360	-	-	-	-	-	-	-	1,6	1,5	1,4
370	-	-	-	-	-	-	-	1,6	1,5	1,4
380	-	-	-	-	-	-	-	1,7	1,5	1,4
390	-	-	-	-	-	-	-	1,7	1,5	1,4
400	-	-	-	-	-	-	-	1,7	1,5	1,4
410	-	-	-	-	-	-	-	1,7	1,6	1,4
420	-	-	-	-	-	-	-	1,7	1,6	1,5
430	-	-	-	-	-	-	-	-	1,6	1,5
440	-	-	-	-	-	-	-	-	1,6	1,5
450	-	-	-	-	-	-	-	-	1,6	1,5
453	-	-	-	-	-	-	-	-	1,6	1,5



 Tarih: 13/03/2024

EK-29-E ADIM 5&6 /ANNEX-29-E STEP 5&6

60 Dakika

Fire Resistance Period / Yangına Daynım Periyodu 60 minutes/dakika										
Design Temperature/ Dizayn Sıcaklığı °C	300	350	400	450	500	550	600	650	700	750
Section factor/Kesit faktörü m ⁻¹	Thickness (mm) of Fire Protection Material to Maintain Steel Temperature Below Design Temperature/Çeliği istenilen dizayn sıcaklığı altında tutmak için koruma malzemesi kalınlığı (mm)									
71	-	-	-	-	1,6	1,5	1,4	1,4	1,4	1,4
80	-	-	-	-	-	1,6	1,4	1,4	1,4	1,4
90	-	-	-	-	-	1,6	1,5	1,4	1,4	1,4
100	-	-	-	-	-	-	1,6	1,4	1,4	1,4
110	-	-	-	-	-	-	1,6	1,5	1,4	1,4
120	-	-	-	-	-	-	1,7	1,5	1,4	1,4
130	-	-	-	-	-	-	-	1,6	1,5	1,4
140	-	-	-	-	-	-	-	1,6	1,5	1,4
150	-	-	-	-	-	-	-	1,7	1,5	1,4
160	-	-	-	-	-	-	-	-	1,6	1,5
170	-	-	-	-	-	-	-	-	1,6	1,5
180	-	-	-	-	-	-	-	-	1,6	1,5
190	-	-	-	-	-	-	-	-	1,7	1,5
200	-	-	-	-	-	-	-	-	1,7	1,6
210	-	-	-	-	-	-	-	-	-	1,6
220	-	-	-	-	-	-	-	-	-	1,6
230	-	-	-	-	-	-	-	-	-	1,6
240	-	-	-	-	-	-	-	-	-	1,6
250	-	-	-	-	-	-	-	-	-	1,7
260	-	-	-	-	-	-	-	-	-	1,7
270	-	-	-	-	-	-	-	-	-	1,7
280	-	-	-	-	-	-	-	-	-	-
290	-	-	-	-	-	-	-	-	-	-
300	-	-	-	-	-	-	-	-	-	-
310	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-
350	-	-	-	-	-	-	-	-	-	-
360	-	-	-	-	-	-	-	-	-	-
370	-	-	-	-	-	-	-	-	-	-
380	-	-	-	-	-	-	-	-	-	-
390	-	-	-	-	-	-	-	-	-	-
400	-	-	-	-	-	-	-	-	-	-
410	-	-	-	-	-	-	-	-	-	-
420	-	-	-	-	-	-	-	-	-	-
430	-	-	-	-	-	-	-	-	-	-
440	-	-	-	-	-	-	-	-	-	-
450	-	-	-	-	-	-	-	-	-	-
453	-	-	-	-	-	-	-	-	-	-



Takip no: 137384
Order no: 137384

EK-29-F ADIM 5&6 /ANNEX-29-F STEP 5&6

90 Dakika

Fire Resistance Period / Yangına Daynım Periyodu 90 minutes/dakika										
Design Temperature/ Dizayn Sıcaklığı °C	300	350	400	450	500	550	600	650	700	750
Section factor/Kesit faktörü m ⁻¹	Thickness (mm) of Fire Protection Material to Maintain Steel Temperature Below Design Temperature/Çeliği istenilen dizayn sıcaklığı altında tutmak için koruma malzemesi kalınlığı (mm)									
71	-	-	-	-	-	-	-	-	1,6	1,5
80	-	-	-	-	-	-	-	-	1,7	1,6
90	-	-	-	-	-	-	-	-	-	1,6
100	-	-	-	-	-	-	-	-	-	-
110	-	-	-	-	-	-	-	-	-	-
120	-	-	-	-	-	-	-	-	-	-
130	-	-	-	-	-	-	-	-	-	-
140	-	-	-	-	-	-	-	-	-	-
150	-	-	-	-	-	-	-	-	-	-
160	-	-	-	-	-	-	-	-	-	-
170	-	-	-	-	-	-	-	-	-	-
180	-	-	-	-	-	-	-	-	-	-
190	-	-	-	-	-	-	-	-	-	-
200	-	-	-	-	-	-	-	-	-	-
210	-	-	-	-	-	-	-	-	-	-
220	-	-	-	-	-	-	-	-	-	-
230	-	-	-	-	-	-	-	-	-	-
240	-	-	-	-	-	-	-	-	-	-
250	-	-	-	-	-	-	-	-	-	-
260	-	-	-	-	-	-	-	-	-	-
270	-	-	-	-	-	-	-	-	-	-
280	-	-	-	-	-	-	-	-	-	-
290	-	-	-	-	-	-	-	-	-	-
300	-	-	-	-	-	-	-	-	-	-
310	-	-	-	-	-	-	-	-	-	-
320	-	-	-	-	-	-	-	-	-	-
330	-	-	-	-	-	-	-	-	-	-
340	-	-	-	-	-	-	-	-	-	-
350	-	-	-	-	-	-	-	-	-	-
360	-	-	-	-	-	-	-	-	-	-
370	-	-	-	-	-	-	-	-	-	-
380	-	-	-	-	-	-	-	-	-	-
390	-	-	-	-	-	-	-	-	-	-
400	-	-	-	-	-	-	-	-	-	-
410	-	-	-	-	-	-	-	-	-	-
420	-	-	-	-	-	-	-	-	-	-
430	-	-	-	-	-	-	-	-	-	-
440	-	-	-	-	-	-	-	-	-	-
450	-	-	-	-	-	-	-	-	-	-
453	-	-	-	-	-	-	-	-	-	-



Talep no:
Order no: 139304